


- PAINTED STORAGE DRAWER.
- DOOR SLIDING STEEL WITH WEATHER-STRIPPING, BALL BEARING HANGERS, HEAVY DUTY TRACK, SAFETY GLAZING, HOOK BOLT LOCK WITH REMOVABLE CYLINDER, AND INSIDE THUMB TURN.
- 4. 2" DIAMETER HOLE IN COUNTER FOR DROP CORDS.
- 5. HAZARDOUS LOCATION 100 WATT INCANDESCENT LIGHT.
- 6. HAZARDOUS LOCATION WALL SWITCH FOR INTERIOR LIGHT.
- 7. OPTIONAL HAZARDOUS LOCATION HEATER
- 8. HAZARDOUS LOCATION JUNCTION BOX FOR WIRING TERMINATION.
- 9. ANCHOR CLIP 2" X 2" X ¼"(MIN) STEEL WITH A ¾" ANCHOR BOLT HOLE, 4-REQ"D, WELDED TO BASE AT GRADE. ANCHOR BOOTH AFTER FINAL LOCATION. ANCHOR BOLTS NOT INCLUDED.

NOTE: PAR-KUT BOOTHS ARE OF SINGLE UNIT WELDED STEEL CONSTRUCTION, FACTORY ASSEMBLED AND DELIVERED SET UP. FAILURE TO SECURELY ANCHOR BOOTH MAY RESULT IN OVERTURNING OF UNIT AND SERIOUS INJURY TO OCCUPANT.

- A. GLAZING SAFETY GLAZING SET IN ANODIZED ALUMINUM WINDOW FRAMES.
- B. PAINT FINISH SHALL BE SINGLE COLOR OF CHOICE, IMRON POLYURETHANE HIGH GLOSS
 INDUSTRIAL COATING. SHALL BE APPLIED TO ALL EXPOSED METAL SURFACES. THIS EXCLUDES
 ROOF SURFACE, ANODIZED ALUMINUM WINDOW FRAMES AND ANY STAINLESS STEEL COMPONENTS (IF
 USED).
- C. ELECTRICAL ALL WIRING BY PAR-KUT TO BE #12(MIN) STRANDED COPPER, THHN ENCLOSED IN **(MIN) RIGID CONDUIT PER NATIONAL ELECTRIC CODE. FITTINGS, FIXTURES, AND DEVICES ARE U.L. LABELED. ALL WIRING TO TERMINATE AT JUNCTION BOX #8. ALL ELECTRICAL DEVICES TO BE RATED CLASS 1, DIVISION II, GROUPS C&D.
- D. BOOTH WILL HAVE A 3" CANDPY OVERHANG ON ALL SIDES.
- E. LIFTING RING(S) ARE PROVIDED ON ROOF.
- F. NO ON SITE WORK BY PAR-KUT.



PAR-KUT INTERNATIONAL, INC. 40961 Production Drive Harrison Twp. Mich. 48045-1351 PH. (586) 468-2947 www.parkut.com



PWG#pK64-XPL|SHEET A-1 4' X 6' EXPLOSION PROOF BOOTH

SCALE DRAWN BY REVISED JJD .

DATE 11-17-2014 4' X 6' CHK'D BY: SALES REPRESENTATIV

PAINT COLOR: (PLEASE SPECIFY COLOR)

GENERAL NOTES